

STATE OF MISSOURI  
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



**MISSOURI STATE OPERATING PERMIT**

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

Permit No. MO-0085472

Owner: Duckett Creek Sanitary District (DCSD)  
Address: 3550 Highway K, O'Fallon, MO 63304

Continuing Authority: Same as above  
Address: Same as above

Facility Name: DCSD, Treatment Plant #1  
Address: 2950 Greens Bottom Road, St. Charles, MO 63303

Legal Description: SW ¼, Sec. 23, T46N, R4E, St. Charles County

Receiving Stream: Tributary to Dardenne Creek (U)  
First Classified Stream and ID: Missouri River (P)(01604)  
USGS Basin & Sub-watershed No.: (10300200-170001)


is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

**FACILITY DESCRIPTION**

Outfall #001 - POTW - SIC #4952  
Oxidation ditch/aerobic sludge digestion/sludge is being land applied.  
Design population equivalent is 50,000.  
Design flow is 5.0 MGD. Actual flow is 4.8 MGD.  
Design sludge production is 1.05 dry tons/year.  
Outfalls #002, #003 & #004 - POTW - SIC #1541  
Stormwater runoff.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

February 20, 2004  
Effective Date

  
Stephen M. Manford, Director, Department of Natural Resources  
Executive Secretary, Clean Water Commission

February 19, 2009  
Expiration Date  
MO 780-0041 (10-93)

Mohamad Alhalabi, P.E., Director, St. Louis Regional Office

					PAGE NUMBER 2 of 7	
<b>A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS</b>					PERMIT NUMBER MO-0085472	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	once/daily	24 hr. total
Biochemical Oxygen Demand <sub>5</sub> ***	mg/L		45	30	once/week	24 hr. composite
Total Suspended Solids***	mg/L		45	30	once/week	24 hr. composite
pH - Units	SU	**		**	once/week	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>April 28, 2004</u> .						
Oil and Grease	mg/L	15		10	once/quarter****	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>July 28, 2004</u> .						
Whole Effluent Toxicity (WET) Test	% Survival	See Special Conditions			once/year	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED <u>ANNUALLY</u> ; THE FIRST REPORT IS DUE <u>October 28, 2004</u> .						
<u>Outfalls #002, 003 &amp; 004</u>						
Flow	MGD	*		*	once/year*****	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub>	mg/L	*		*	once/year*****	grab
Total Suspended Solids	mg/L	*		*	once/year*****	grab
pH - Units	SU	**		**	once/year*****	grab
Oil and Grease	mg/L	15		10	once/year*****	grab
Total BETX*****	mg/L	0.75		0.75	once/year*****	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>ANNUALLY</u> ; THE FIRST REPORT IS DUE <u>October 28, 2004</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<b>B. STANDARD CONDITIONS</b>						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II &amp; III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- \* Monitoring requirement only.
- \*\* pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.
- \*\*\* This facility is required to meet a removal efficiency of 85% or more.
- \*\*\*\* Sample once per quarter in the months of January, April, July, and October.
- \*\*\*\*\* Permittee shall collect and analyze one sample per year, taken during a rainfall which exceeds 0.1 inches and results in a discharge, and also at any time at the request of the department.
- \*\*\*\*\* Total BETX shall be measured as the sum of Benzene, Ethylbenzene, Toluene, and Xylene.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
  - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.
2. All outfalls must be clearly marked in the field.
3. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
    - (1) One hundred micrograms per liter (100 µg/L);
    - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
    - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
    - (4) The level established in Part A of the permit by the Director.
  - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
4. Report as no-discharge when a discharge does not occur during the report period.

C. SPECIAL CONDITIONS (continued)

5. General Criteria. The following water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
- (a) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
  - (b) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
  - (c) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
  - (d) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
  - (e) There shall be no significant human health hazard from incidental contact with the water;
  - (f) There shall be no acute toxicity to livestock or wildlife watering;
  - (g) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
  - (h) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
6. Special Condition - Sewer Extension

The department has approved the construction permit program to regulate and approve construction of sanitary sewers which are tributary to this wastewater treatment plant. This approval may be modified or revoked by the department if the sewage collection, transportation, or treatment facilities reach their design limitations, if the facility falls into chronic noncompliance with the permit, or if the permittee fails to follow the terms and conditions of the submitted and approved program.

This permit may be reopened and modified or alternatively revoked and reissued to incorporate new or modified conditions to the sewer construction permit authority, if information indicates changes are necessary to assure compliance with Missouri's Clean Water Law and associated regulations.

When any of the above mentioned conditions occur, the permittee will be notified prior to any modification of this permit condition.

An annual report on the sewer extension program must be submitted by January 28 of each year to the Missouri Department of Natural Resources Regional Office. The report must list the name of the projects approved and the length of sewers and force mains and the capacity of lift stations constructed under the sewer extension program. Also what, if any, inspections were made during construction and the findings, the results of leakage and deflection tests and the average and design wastewater flows (design P.E.). A summary of total flow at the treatment facility and a discussion regarding possible implications on operations and maintenance shall be included.

C. SPECIAL CONDITIONS (continued)

7. Whole Effluent Toxicity (WET) tests will be conducted as follows:

SUMMARY OF WET TESTING FOR THIS PERMIT				
OUTFALL	A.E.C. %	FREQUENCY	SAMPLE TYPE	MONTH
#001	10%	Annually	24 hr. composite	April

(a) Test Schedule and Follow-Up Requirements

- (1) Perform a single-dilution test in the months and at the frequency specified above. If the effluent passes the test, do not repeat the test until the next test period.  
Submit test results along with complete copies of the test reports as received from the laboratory within 30 calendar days of availability to the WPCP, Planning Section, P.O. Box 176, Jefferson City, MO 65102.
- (2) If the effluent fails the test, a multiple dilution test shall be performed within 30 calendar days , and biweekly thereafter, until one of the following conditions are met:
  - (a) THREE CONSECUTIVE MULTIPLE-DILUTION TESTS PASS. No further tests need to be performed until next regularly scheduled test period.
  - (b) A TOTAL OF THREE MULTIPLE-DILUTION TESTS FAIL.
- (3) The permittee shall submit a summary of all test results for the test series along with complete copies of the test reports as received from the laboratory to the WPCP, Planning Section, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the third failed test.
- (4) Additionally, the following shall apply upon failure of the third test: A toxicity identification evaluation (TIE) or toxicity reduction evaluation (TRE) is automatically triggered. The permittee shall contact WPCP, Planning Section to ascertain as to whether a TIE or TRE is appropriate . The permittee shall submit a plan for conducting a TIE or TRE to the Planning Section of the WPCP within 60 calendar days of the date of DNR's direction to perform either a TIE or TRE. This plan must be approved by DNR before the TIE or TRE is begun. A schedule for completing the TIE or TRE shall be established in the plan approval.
- (5) Upon DNR's approval, the TIE/TRE schedule may be modified if toxicity is intermittent during the TIE/TRE investigations. A revised WET test schedule may be established by DNR for this period.
- (6) If a previously completed TIE has clearly identified the cause of toxicity, additional TIEs will not be required as long as effluent characteristics remain essentially unchanged and the permittee is proceeding according to a DNR approved schedule to complete a TRE and reduce toxicity. Regularly scheduled WET testing as required in the permit, without the follow-up requirements, will be required during this period.
- (7) All failing test results shall be reported to WPCP, Planning Section, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the availability of the results.
- (8) When WET test sampling is required to run over one DMR period, each DMR report shall contain information generated during the reporting period.
- (9) Submit a concise summary of all test results with the annual report.

C. SPECIAL CONDITIONS (continued)

8. Whole Effluent Toxicity (WET)

(b) PASS/FAIL procedure and effluent limitations:

- (1) To pass a single-dilution test, mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level;  $p = 0.05$ ) than that observed in the upstream receiving-water control sample. The appropriate statistical tests of significance will be those outlined in the most current USEPA acute toxicity manual or those specified by the MDNR.
- (2) To pass a multiple-dilution test:
  - (a) the computed percent effluent at the edge of the zone of initial dilution, Acceptable Effluent Concentration (AEC), must be less than three-tenths (0.3) of the  $LC_{50}$  concentration for the most sensitive of the test organisms; or,
  - (b) all dilutions equal to or greater than the AEC must be nontoxic. Failure of one multiple-dilution test is an effluent limit violation.

(c) Test Conditions

- (1) Test Type: Acute Static non-renewal
- (2) Test species: Ceriodaphnia dubia and Pimephales promelas (fathead minnow). Organisms used in WET testing shall come from cultures reared for the purpose of conducting toxicity tests and cultured in a manner consistent with the most current USEPA guidelines. All test animals shall be cultured as described in the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms.
- (3) Test period: 48 hours at the "Acceptable Effluent Concentration" (AEC) specified above.
- (4) When dilutions are required, upstream receiving stream water shall be used as dilution water. If upstream water is unavailable or if mortality in the upstream water exceeds 10%, "reconstituted" water will be used as dilution water. Procedures for generating reconstituted water will be supplied by the MDNR upon request.
- (5) Single-dilution tests will be run with:
  - (a) Effluent at the AEC concentration;
  - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
  - (c) reconstituted water.
- (6) Multiple-dilution tests will be run with:
  - (a) 100%, 50%, 25%, 12.5%, and 6.25% effluent, unless the AEC is less than 25% effluent, in which case dilutions will be 4 times the AEC, two times the AEC, AEC, 1/2 AEC and 1/4 AEC;
  - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
  - (c) reconstituted water.
- (7) If reconstituted-water control mortality for a test species exceeds 10%, the entire test will be rerun.

#### SUMMARY OF TEST METHODOLOGY FOR WHOLE-EFFLUENT TOXICITY TESTS

Whole-effluent-toxicity test required in NPDES permits shall use the following test conditions when performing single or multiple dilution methods. Any future changes in methodology will be supplied to the permittee by the Missouri Department of Natural Resources (MDNR). Unless more stringent methods are specified by the DNR, the procedures shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms,

##### Test conditions for Ceriodaphnia dubia:

Test duration:	48 h
Temperature:	25 ± 1°C Temperatures shall not deviate by more than 3°C during the test.
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light, 8 h dark
Size of test vessel:	30 mL (minimum)
Volume of test solution:	15 mL (minimum)
Age of test organisms:	<24 h old
No. of animals/test vessel:	5
No. of replicates/concentration:	4
No. of organisms/concentration:	20 (minimum)
Feeding regime:	None (feed prior to test)
Aeration:	None
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p < 0.05$ )
Test acceptability criterion:	90% or greater survival in controls

##### Test conditions for (Pimephales promelas):

Test duration:	48 h
Temperature:	25 ± 1°C Temperatures shall not deviate by more than 3°C during the test.
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light/ 8 h dark
Size of test vessel:	250 mL (minimum)
Volume of test solution:	200 mL (minimum)
Age of test organisms:	1-14 days (all same age)
No. of animals/test vessel:	10
No. of replicates/concentration:	4 (minimum) single dilution method 2 (minimum) multiple dilution method
No. of organisms/concentration:	40 (minimum) single dilution method 20 (minimum) multiple dilution method
Feeding regime:	None (feed prior to test)
Aeration:	None, unless DO concentration falls below 4.0 mg/L; rate should not exceed 100 bubbles/min.
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p < 0.05$ )
Test Acceptability criterion:	90% or greater survival in controls